

CERTIFICATE

15632 1511 07A

according to EN 15632-1:2009 & EN 15632-3:2010

for

pre-insulated flexible non-bonded pipe system

with plastic service pipe:

MICROFLEX[®]

by order of

Watts Industries Italia S.r.l.

This certificate is based on report 1298E5175 dated from 2011-11-05.

This certificate covers MICROFLEX[®] pipes those consist of one service pipe of peroxide cross-linked polyethylene (PE-Xa) with an oxygen diffusion barrier, a thermal insulation of polyolefine foam and a black colored casing of high density polyethylene (HDPE) with ≥ 2 % carbon black as UV stabilizer.

MICROFLEX[®] pipes described above meet requirements given in EN 15632-1:2009 & EN 15632-3:2010.

Hemmingen, 2015-11-05



Thomas Grage
Managing Director



FFI FERNWÄRME
FORSCHUNGSINSTITUT
GmbH

Max-von-Laue-Str. 23
30966 Hemmingen
+49 511 94370 0
www.fernwaerme.de



Sönke Kraft
Project Manager